

**FUEL OIL (EXCERPT)**  
**Act 319 of 1929**

**125.567 Underground tanks incased.**

Sec. 17. Underground tanks located within 10 feet of a basement or pit lower than the top of such tank, shall be completely incased in 6 inches of concrete of a 1, 3 and 5 mixture.

**History:** 1929, Act 319, Imd. Eff. May 28, 1929;—CL 1929, 2624;—CL 1948, 125.567.