

HOUSE BILL No. 4946

September 4, 2013, Introduced by Rep. Geiss and referred to the Committee on Regulatory Reform.

A bill to amend 1941 PA 207, entitled "Fire prevention code," by amending section 5c (MCL 29.5c), as amended by 2006 PA 189.

THE PEOPLE OF THE STATE OF MICHIGAN ENACT:

1 Sec. 5c. (1) A person shall not establish or maintain 1 or
2 more of the following without obtaining a certificate from the
3 ~~department of environmental quality~~**BUREAU:**

4 (a) A flammable compressed gas or liquefied petroleum gas
5 container filling location.

6 (b) An aboveground flammable compressed gas or liquefied
7 petroleum gas storage location that has a tank with a water
8 capacity of more than 2,000 gallons or has 2 or more tanks with an
9 aggregate water capacity of more than 4,000 gallons.

10 (c) An aboveground storage location for a flammable liquid or
11 combustible liquid that has an individual tank storage capacity of

1 more than 1,100 gallons. Crude petroleum collection tanks that
2 receive crude petroleum directly from a wellhead and are certified
3 by the ~~department of environmental quality~~ **BUREAU** may be maintained
4 without further inspection by the ~~department of environmental~~
5 ~~quality,~~ **BUREAU**, except as the ~~department of environmental quality~~
6 **BUREAU** considers necessary to ~~assure~~ **ENSURE** compliance with this
7 act.

8 (2) The ~~department of environmental quality~~ **BUREAU** may require
9 that a person obtain approval from the ~~department of environmental~~
10 ~~quality~~ **BUREAU** before the installation of an aboveground storage
11 tank for flammable or combustible liquids that has an individual
12 tank storage capacity of 1,100 gallons or less. However, this
13 requirement does not apply to farm location storage tanks of 1,100
14 gallons or less capacity used for storing motor fuel for
15 noncommercial purposes or heating oil for consumptive use on the
16 premises where stored.

17 (3) **A PERSON SHALL NOT STORE A CONTAINER THAT HOLDS 2 POUNDS**
18 **OR MORE, BY WEIGHT, OF FLAMMABLE COMPRESSED GAS OR LIQUEFIED**
19 **PETROLEUM GAS FOR SALE IN OR WITHIN 50 FEET OF A BUILDING THAT IS**
20 **OPEN TO THE PUBLIC.**