

BOILER ACT OF 1965 (EXCERPT)
Act 290 of 1965

***** 408.756 THIS SECTION IS REPEALED BY ACT 407 OF 2016 EFFECTIVE APRIL 4, 2017 *****

408.756 Maximum allowable pressure; safety standards; sale or reinstallation.

Sec. 6. (1) The maximum allowable pressure of a boiler carrying the American society of mechanical engineers' code symbol shall be determined by the applicable sections of the code under which it was constructed and stamped.

(2) The maximum allowable pressure of a boiler which does not carry the American society of mechanical engineers' code symbol may be computed in accordance with the inspection code of the national board of boiler and pressure vessel inspectors.

(3) This act shall not be construed as in any way preventing the use, sale or reinstallation of an existing boiler, if it has been made to conform to the rules and regulations of the board governing existing installations, if it has been found upon inspection to be in a safe condition.

History: 1965, Act 290, Eff. July 1, 1966.